



## Fire Protection

- ALL concession vendors must comply with the codes for combustibles, canopies, fuel tanks for cooking, fire extinguishers and solid fuel.
- All concession Vendors that have an open flame or other device emitting flame or fire will have the appropriate fire Extinguisher based the type of environment NC fire code requirements
- All concession vendors are required to have a portable fire extinguisher that has affixed a current inspection tag that carries a minimum of a 2A - 10B or 2A - 10B(C) rating (ABC Rated). For those vendors using cooking oil, fats, or greases in a deep well fryer or cook top are required to have a Class K fire extinguisher. Residential extinguishers are NOT acceptable.
- All Fire Extinguishers must have a current inspection date within one year of festival date.
- All propane tanks must be firmly secured on a hard, noncombustible surface that cannot be knocked over. Vendors must supply their own surface on which to secure tanks; the ground alone does not qualify. Bungee cords are not an acceptable form of securing propane tanks.
- Propane tanks need to be 10 feet away from electrical meters, open flame, freezers and refrigerators and per Fire Code, 10 feet from your tent.
- All vendors must comply with instructions from the Fire Marshall. Failure to do so may result in expulsion from the festival.
- All fire lanes must remain open at all times.
- Vendors who have a vendor space located next to a fire break or lane must keep the area clear at all times. Fire Marshall and festival staff will be inspecting these areas.